

Schena, Cristeen

From: Aram Varjabedian <avarjabedian@woodardcurran.com>
Sent: Wednesday, March 30, 2016 1:28 PM
To: Turin, David; Burns, David (DEP); Joyce, Ryan (FWE); jsullivan@town.hull.ma.us
Cc: Dow, James; Frank Cavaleri
Subject: 28 Winthrop Ave., Hull, MA - SSO; Permit No. MA0101231
Attachments: 03-29-2016-MH-20169-Manhole-Inspection.pdf

Good afternoon:

I am writing to inform you of an SSO that occurred at 28 Winthrop Ave. in Hull, MA. Homeowner had a back-up into basement, called a plumber, who snaked out the line. The plumber then contacted us to inform us that additional checking was necessary. We took the call at 1:27pm on 3/29/16. We dispatched our staff, who surveyed the area manholes and found that the manhole where this home's lateral discharged into was full of debris. A call to Rosano-Davis Pumping was made to clean out the manhole. While waiting for the pump truck, the staff was able to clear the blockage to allow for flow to leave the manhole. We were updated by the plumber that some sewage did back up into the home's basement, and that this was cleaned up by a cleaning company. Approximate quantity 25-50 gallons. Not a confirmed amount.

We will follow up with the full SSO form/report.

Sincerely,

Aram

Aram Varjabedian
Plant Manager
Hull Wastewater Treatment Facility
1111 Nantasket Avenue | Hull, MA 02045
Phone 781.925.0906 | Fax 781.925.3056 | Cell 339.214.8334
www.woodardcurran.com



COMMITMENT & INTEGRITY DRIVE RESULTS